

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**

**Periodical Renewal Fire Certificate**

From:  
District Disaster Response & Fire Officer  
Andhra Pradesh, Bapatla

To:  
DISRICT FIRE OFFICER,

**File No: 27886/BPT/DFO/2025, Date:13/09/2025**  
**Occupancy NoC RC Number: 2202/OGL/DFO/2018**

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **PRIDE E.M HIGHSCHOOL, represented by BALAPALLI ASHOK BABU, Ashok Nagar,Karamchedu Road,DONO35/2A,WARD NO25,CHIRALA,BAPATALA** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
  2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
  3. This Office NOC for Occupancy Rc No. 2202/OGL/DFO/2018, Dt.29/03/2018
  4. Renewal NOC For Occupancy 2202/OGL/DFO/2018, Dt.28/03/2019
  5. Online Application for Renewal NOC of BALAPALLI ASHOK BABU, Ashok Nagar,Karamchedu Road,DONO35/2A,WARD NO25,CHIRALA,BAPATALA - Inspection report called for Regarding.
  6. Online Inspection Report submitted by Officers of this Department on 10-09-2025.

-- x --

The Management of PRIDE E.M HIGHSCHOOL, represented by BALAPALLI ASHOK BABU, Ashok Nagar,Karamchedu Road,DONO35/2A,WARD NO25,CHIRALA,BAPATALA has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.25693/- vide challan No. 90097726812025, Dated 03/09/2025 at ONLINE, ONLINE.

**B-1**

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **BALAPALLI ASHOK BABU Ashok Nagar,Karamchedu Road,DONO35/2A,WARD NO25,CHIRALA,BAPATALA**, subject to the following conditions.

SI	As Builder	As Occupant	As Security Personnel
----	------------	-------------	-----------------------

1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 13/09/2025 to 12/09/2026.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.


6. Challan Info:

Challan Number	Challan Date	Challan Amount
90097726812025	03/09/2025	25693

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The Inspection Committe has tested the Fire Fighting Equipment and found that they are in good working condition. Hence recommended for renewal of No Objection Certificate. This Certificate is only in Fire Point of View. Not for Ownership Transfer. The management should maintain the Fire Fighting Equipment in Good working Condition.

Your Sincerely,

  
District Disaster Response & Fire Officer, Andhra Pradesh, Bapatla  
13/09/2025

Copy to Management BALAPALLI ASHOK BABU, BALAPALLI ASHOK  
BABU,DNO35/2A.WARDNO:31,CHIRALA MUNICIPALITY, CHIRALA523157

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

Copy to The Inspection Committe has tested the Fire Fighting Equipment and found that they are in good working condition. Hence recommended for renewal of No Objection Certificate. This Certificate is only in Fire Point of View. Not for Ownership Transfer. The management should maintain the Fire Fighting Equipment in Good working Condition.